



Declaration of Hygiene Conformity

Active Chilled Beams Type DID312 without Condensate Drip Tray

Object of the inspection

TROX GmbH, Heinrich-Trox-Platz, D-47504 Neukirchen-Vluyn, Germany, hereby confirm that the active chilled beams of type DID312 without condensate drip tray meet the hygiene requirements specified by the standards and regulations listed below.

- European standard
 - EN 13779 (09/2007)
- German standards
 - VDI 6022, part 1 (07/2011)
 - VDI 3803 (02/2010)
- Austrian standards
 - ÖNORM H 6021 (09/2003)
- Swiss SWKI regulations
 - VA104-01 (04/2006)

For the purpose of this declaration of conformity a sample of each type mentioned above was viewed at the TROX GmbH factory, Heinrich-Trox-Platz, 47504 Neukirchen-Vluyn, Germany, and related data sheets, technical literature, and inspection reports were appraised.

Summary of the test result

The examination of the above-mentioned sample equipment and the appraisal of the available documents have shown that the hygiene requirements specified by the above-mentioned standards and regulations are met.

We hereby confirm that the active chilled beams of type DID312 without condensate drip tray meet the hygiene requirements of the specified standards and regulations.

Neukirchen-Vluyn, Germany, 08 November 2011

Dipl.-Ing. Dirk Scherder
trained according to VDI 6022, category A
Product Management

Dipl.-Ing. Jan Heymann
Manager Quality Systems

Certificate